



# NATIONAL INSTITUTE OF UNANI MEDICINE

Kottigepalya, Magadi Main Road, Bangalore – 560 091  
(An autonomous body under Ministry of Ayush, Govt. of India)  
(Accredited to NABH)



Tel : 080-23584260

Fax : 080 -23584180

Date. 05/07/2021.

F.No.115-2/2021-21/Accts/NIUM/

To,

**Subject: Invitation of Quotation for Supply & Installation of 500 LPH Ro Water Plant for Girls Hostel, Admn. & Academic Section, NIUM : – reg.**

\*\*\*\*\*

Sir,

With reference to the subject mentioned above, Quotations are invited from reputed registered Service Providers for the Supply & Installation of 500 LPH Ro Water Plant for Girls Hostel, Admn. & Academic Section, NIUM as detailed below.

Sl. No	Name of the Items	Specification /Make	Quantity Required.	Amount (₹)	Total GST Amount (₹)	Grant Total (₹)
01	Ro Water Plant	500 LPH Ro Water Plant Technical Specification:- <b>1.Multi Grade Pressure Sand Filter</b> Capacity: 2000 LPH Size: 1248 Material: FRP Valves: Top mounted filter valve (Automatic) Quantity: 1 no. Brand: Pentair <b>2.Multi Grade Pressure Carbon Filter:</b> Capacity: 2000 LPH Size: 1248 Material: FRP Valves: Top mounted filter valve (Automatic) Quantity: 1 no. Brand: Pentair <b>3.Micron Filter:</b> Flow rate: 2000 LPH Length of cartridge: 20 inches Material: HDPE No. of cartridges: 2 Nos Type: PP Wound Quantity: 2 Nos <b>4.Antiscalant Dosing System:</b> To dosing of anti scale to avoid scale formation on membrane to enhance more life to membrane at the rate of 1 to 6 Lph. Dosing : Sintex Capacity: 100 Litters Quantity: 1 Nos <b>5.High Pressure Pump:</b> Capacity: 2/11 Quantity: 1 Nos	03 No's.			

	<p>Make: CRI</p> <p><b>6.Reverse Osmosis Housing:</b>  Membren Housing: FRP/SS  Membren: Filmtec/GE  Quantity: 2 Nos</p> <p><b>7.Reverse Osmosis Membren</b>  Membren: FRP  Membren: Filmtec / Equal  Quantity: 2 Nos  Membren Type: 4040</p> <p><b>8.Panel board with instruments</b>  Flow meter: 2 Nos  Pressure gauge: 2 Nos  Float valves: 2 Nos</p> <p><b>9.SS Skid</b>  To mount all the parts with perfect design to work efficiently 304 grade skid.</p> <p><b>10.Stroge Tank with stand</b>  Capacity: 1000 Litters  Skid: 304 grade</p> <p><b>11.Raw Water Pump</b>  Capacity: 0.5/1 HP  Make: CRI</p> <p><b>12.Toatl Piping in CPVC</b></p> <p><b>13. UV System (SS 304)</b>  And other accessories</p>		
--	---	--	--

The quotations may be submitted in a sealed cover quoting the competitive rate with above specification by clearly mentioning taxes applicable if any., time required for supply and Installation the items with the terms & conditions, Copy of GST

Wherever required Test Certificate should be sent along with relevant document

Incomplete bids are liable for rejection. Late / delayed offer will not be considered.

NIUM reserves the right to reject any or all tender without assigning any reason.


If the item is not supplied within stipulated period and not as per specification, NIUM is having right to accept or reject whole lot or part of it.

In case the items are not supplied in time, Penalty of 5% for delay upto 15 days from the last date & 10% beyond 15 days upto one month shall be levied. If the firm fails to supply the items as per Supply Order, the item will be procured from other bidder & the difference amount shall be recovered from the bill of the firm or otherwise.

The envelope containing quotation should be super scribed as **"Quotation for Supply & Installation of 500 LPH Ro Water Plant for Girls Hostel, Admn. & Academic Section, NIUM"**

The last date for the submission of quotation is: 15/07/2021.

Yours faithfully,

  
(Suresha)  
Accounts Officer

**Distribution :**

1. Dr. Renuka B.N, Warden Girls Hostel, for information
2. Website in-charge for information and to upload quotation in NIUM- website.
3. Concern file.
4. Guard file.